

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection household and similar installations (CBOs)

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.  
No. 288 Wei 17<sup>th</sup> Road, Yueqing Economic Development Zone,  
Yueqing, Wenzhou, Zhejiang,  
China

Name and address of the manufacturer

Hangzhou Taimu Electrical Co., Ltd.  
No. 157 Longchuanwu Road, Yuhang Economic Development  
Area, Hangzhou,  
China

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as manufacturer

Ratings and principal characteristics

Un= 240/415V~ (1P), 415V~ (2P, 3P, 4P), 50/60Hz,  
In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A;  
B-, C- and D- Type  
Icn= 10000A, Ics= 7500A, Energy limiting class 3

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKM2-63H

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

210302557SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

intertek

Signature:

Henrik Wikström

Date: 08 June, 2021