



Ref. Certif. No.

SE-96483

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded case circuit-breakers (MCCB)
Name and address of the applicant	Zhejiang ETEK Electrical technology Co., Ltd. No. 288 Wei 17th Road, Yueqing Economic Development Zone Yueqing, Wenzhou, Zhejiang Province P.R. China
Name and address of the manufacturer	Shanghai Dada Electric Co., Ltd. No. 171, Yezhuang Road, Zhuanghang, Fengxian Shanghai CHINA
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as manufacturer
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	EKM8E-1600S, EKM8E-1600H
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	191200183SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00
Date: 16 December 2019



Signature:

Henrik Wikström

Ratings and principal characteristics

Model:	EKM8E-1600H, EKM8E-1600S
Ue:	400V, 3P
Ratings Current(I _n):	800, 1000, 1250, 1600A; I _r =(0,4-1,0)I _n
I _{cu} (kA):	85kA(EKM8E-1600H), 65kA(EKM8E-1600S)
I _{cs} (kA):	50kA(EKM8E-1600H), 50kA(EKM8E-1600S)
I _{cw} (kA):	20kA/1s
Category:	Cat. B
Frequency:	50/60Hz
Other information:	U _i = 1000V~, U _{imp} =8kV, Ref. temperature: +40°C, +55C

Date: 16 December 2019

 Signature: 