



BV LCIE  
CHINA  
Number

N° 2166AS08ASCQ41629

## ATTESTATION of conformity with European Directives

*Product:* MCB  
*Reference* EKM1-40N  
*Issued to* Zhejiang ETEK Electrical Technology Co.,Ltd.  
*Address* NO.288 Wei 17<sup>th</sup> Road , Yueqing Economic Development Zone  
Yueqing, Wenzhou, Zhejiang Province P.R.China  
*Manufacturer* Zhejiang ETEK Electrical Technology Co.,Ltd.  
Type B and C  
Uc=220/230/240V~(1P+N)  
In=1;2;3;4;6;10;16;20;25;32;40A  
50/60Hz  
*Technical characteristics* Ics=Icn= 6000A  
Energy limit class: 3 (according to EN 60898-1)  
Grid distance: 50mm  
Ui=500V  
Uimp=4kV  
Screw diameter of load terminal =3,9mm

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60898-1:2019	B200069	2021-07-26

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), August 23rd, 2021.

Charlie CHEN  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有  
限公司

Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)