



ATTESTATION of conformity with European Directives

Product: MCB
Reference EKM2-63/ EKM2-63S
Issued to ZHEJIANG ETEK ELECTRICAL TECHNOLOGY CO.,LTD.
Address NO.288 Wei 17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province P.R.China
Manufacturer ZHEJIANG CHANGAN ELECTRICAL ENGINEERING CO.,LTD.
Type C and B
Uc:230/400V for 1P; 400V for 2P/3P/4P
In=1; 2; 3; 4; 6; 10; 16; 20; 25; 32; 40; 50; 63A
Ics=Icn=6000A for EKM2-63
Technical characteristics Ics=Icn=4500A for EKM2-63S
Energy limit class: 1 (according to EN 60898-1)
Grid distance: 55mm
Ui=500V
Uimp=4kV
Screw diameter of terminal =5,0mm

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60898-1:2019	B220010, B220010-A1	2022-02-16, Amendment No.1: 2022-05-07

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), May 17th, 2022.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.