



A P P R O V A L S ®

Certificate of Approval

Certificate No.: SAA-192441-EA

Certificate Holder: Zhejiang Etek Electrical Technology Co., Ltd
NO.288 Wei 17th Road,
Yueqing Economic Development Zone
Yueqing, Wenzhou,
Zhejiang Province,
P.R. China

Class Description: Residual Current Device
Product Description: RCBO
Trade Name: ETEK
Model No.: EKL4-40S
Markings: Ue:240V~ (1P+N)
In: 6, 10, 16, 20, 25, 32, 40A Type B and C
IΔn: 10mA and 30mA
Icn=Ics=4500A and 6000A
Standard: AS/NZS 61009.1:2015
Conditions: Nil

Approval Mark: SAA-192441-EA or RCM

Date First Registered: 23 September 2019
Date of Expiry: 23 September 2024


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-09-19 192441/1